



产品认证证书

证书编号: CQC24001442695

发证日期: 2024年08月22日
有效期至: 2029年08月21日

委托人名称 及注册地址	3Y 电力科技公司 美国加利福尼亚州尔湾镇苯生街 80 号
制造商名称 及注册地址	3Y 电力科技公司 美国加利福尼亚州尔湾镇苯生街 80 号
生产企业名称 及生产地址	深圳辉力电子有限公司 深圳市宝安区新安街道布心社区 73 区流塘路 352 号辉力厂 C4 栋 101 至 301、C5-C11 栋
产品名称和系列、 规格、型号	电源供应器 见附页 (不带电线组件销售, 仅适用于海拔 5000 米及以下)
产品标准和技术要求	GB 17625.1-2022(A 类);GB 4943.1-2022;GB/T 9254.1-2021(A 级)
认证模式	型式试验+获证后监督

上述产品符合 CQC12-045670-2022 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

证书编号: CQC24001442695

第 1 页 / 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

型号	交流输入	直流输出
YSEG1600CM	200-240VAC, 50-60Hz 14A or 240VDC 14A	1600W MAX +12.2V/131A; +12Vsb/3A
YSEG1600AM YSEG1600EM	200-240VAC, 50-60Hz 10A or 240VDC 10A	
YSEG2000CM	200-240VAC, 50-60Hz 14A or 240VDC 14A	2000W MAX +12.2V/164A; +12Vsb/3A
YSEG2000AM YSEG2000EM	200-240VAC, 50-60Hz 10A 220-240VAC, 50-60Hz 10A or 240VDC 10A	1800W MAX +12.2V/147A; +12Vsb/3A 2000W MAX +12.2V/164A; +12Vsb/3A
YSEG2400CM	200-240VAC, 50-60Hz 14A 220-240VAC, 50-60Hz 14A or 240VDC 14A	2160W MAX +12.2V/177A; +12Vsb/3A 2400W MAX +12.2V/196A; +12Vsb/3A



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC24001442695

Valid from: Aug.22,2024

Valid until:Aug.21,2029

NAME AND REGISTERED ADDRESS OF THE APPLICANT 3Y Power Technology Inc.
80 Bunsen Irvine, CA 92618-4210, USA

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER 3Y Power Technology Inc.
80 Bunsen Irvine, CA 92618-4210, USA

NAME AND LOCATION OF THE FACTORY ShenZhen HuiLi Electronics CO.,LTD
Building C4 (101~301) , C5-C11, HuiLi Factory, No. 352 Liutang Road, Area 73, Buxin Community,
Xin 'an Street, Bao 'an District, Shenzhen

PRODUCT NAME, MODEL AND SPECIFICATION POWER SUPPLY
See Appendix (Sale without cord set , Altitude up to 5000m)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB 17625.1-2022(Class A);GB 4943.1-2022;GB/T 9254.1-2021(Class A)

TYPE OF CERTIFICATION SCHEMES type test+follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-045670-2022.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO. : CQC24001442695

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

Model	AC INPUT	DC OUTPUT
YSEG1600CM	200-240VAC, 50-60Hz 14A or 240VDC 14A	1600W MAX +12.2V/131A; +12Vsb/3A
YSEG1600AM YSEG1600EM	200-240VAC, 50-60Hz 10A or 240VDC 10A	
YSEG2000CM	200-240VAC, 50-60Hz 14A or 240VDC 14A	2000W MAX +12.2V/164A; +12Vsb/3A
YSEG2000AM YSEG2000EM	200-240VAC, 50-60Hz 10A 220-240VAC, 50-60Hz 10A or 240VDC 10A	1800W MAX +12.2V/147A; +12Vsb/3A 2000W MAX +12.2V/164A; +12Vsb/3A
YSEG2400CM	200-240VAC, 50-60Hz 14A 220-240VAC, 50-60Hz 14A or 240VDC 14A	2160W MAX +12.2V/177A; +12Vsb/3A 2400W MAX +12.2V/196A; +12Vsb/3A



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE